

**PROFARMA REGARDING SAFE DRINKING WATER SANITARY CONDITION
CERTIFICATE.**

No.- CMO/INSP/2022-23/ 5745

Dated:- 25.01.23

It is Certifide that inspection team headed by Dr. Deshrup Singh from DEPARTMENT OF MEDICAL HEALTH & FAMILY WALFARE, LALITPUR (U.P.) Inspected the DON BOSCO ACADEMY CIVIL LINE, LALITPUR (U.P.) on January , 2023 and found that the DON BOSCO ACADEMY CIVIL LINE, LALITPUR (U.P.) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building &the campus as per the norms prescribed by the the Central/State/U.T Govt.

The above Valod for a period of 1 YEAR

Signature with seal : 25/1/23
मुख्य चिकित्साधिकारी
ललितपुर
Name :Dr. J.S. Bakshi
Desination :CHIEF MEDICAL OFFICER
LALITPUR

To,
Principal,
Don Bosco Academy
Civil Line Lalitpur

J.S. Bakshi
MANAGER
DON BOSCO ACADEMY
LALITPUR (U.P.)

J. Bhatnagar
PRINCIPAL
DON BOSCO ACADEMY
LALITPUR (U.P.)



Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
Babina, Jhansi
MSF-5.10.01



Certificate No. : TC-9907

Report number - C/22-23/01/1599

Date - 28.01.2023

Page No. - 76 (4)

Customer Details

Office Name and Address Don Bosco Academy Civil Lines, Lalitpur

Basic details of sample

District	Lalitpur	Block	-
Gram Panchayat	-	Village	-
Habitation	-	Location	Don Bosco Academy
Source	Bore well	Sample Number	1599
Quantity of sample	1 lit	Date of sample collection	24.01.2023
Sample receiving date	24.01.2023	Name of sample collector	Mr. V. William
Name of Sample depositor	Mr. V. William	Date of Initiation of Test	24.01.2023
Date of Completion of Test	25.01.2023		

Technical Data of Analysis

S. No.	TESTED PARAMETERS	OBSERVED VALUES	SPECIFIED VALUES AS Per BIS 10500:2012		TEST METHOD
			Acceptable Limit	Permissible Limit in the absence of Alternate source	
1	pH	6.89	6.5-8.5	6.5-8.5	IS 3025 (Part 11) M-2- 2012
2	Turbidity (NTU)	0.82	1.0	5.0	IS 3025 (Part 10) : 1984
3	Chloride (mg/l)	41.98	250	1000	IS 3025 (Part 32) : 2014
4	Total Hardness (mg/l)	256.0	200	600	IS 3025 (Part 21) : 2009
5	Calcium as Ca (mg/l)	46.4	75	200	IS 3025 (Part 40) : 1991
7	Magnesium as Mg (mg/l)	34.02	30	100	IS 3025 (Part 46) : 1994
6	Alkalinity (mg/l)	152.0	200	600	IS 3025 (Part 23) : 2008
8	Sulphate (mg/l)	28.90	200	400	IS 3025 (Part 24) M-4-2009
9	TDS (mg/l)	378	500	2000	IS 3025 (Part 16) : 2008
10	Fluoride (mg/l)	0.332	1.0	1.5	IS 3025 (Part 60) :2008
11	Iron (mg/l)	0.20	1.0	1.0	IS 3025 (Part 53) M-6-2003

NOTE:

* These parameter are out of NABL Scope

1- This certificate is only applicable for the above tested parameters.

2- Parameters above permissible limit are bold.

3- This certificate refers only to the particular sample(s) submitted for testing.

4- This certificate shall not be reproduce, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of

5- The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.

6- Sample will be stored up to 7 days (in case of non perishable items only) form the date of issue of tests reports unless other wise specified.

----- End of the Report -----

Issued by

(Anil Kumar Rai)
 Technical Manager
 Mob :-9452592563

MANAGER
DON BOSCO ACADEMY
LALITPUR (I.P.)

PRINCIPAL
DON BOSCO ACADEMY
LALITPUR (I.P.)